

CLASSIFICATION REPORT



Client Name : Porta Finestra Design India Pvt Ltd
Client Address : A823 MIDC TTC Industrial Area,
Off Thane-Belapur Road, Near Fire Brigade Khairane,
Navi Mumbai - 400703, India.
Test Report No : WTIPL-2023-042
Date of Issue : 04 Apr 2023 No. of Pages: 31
Product Name : ZZ47 FRAME ZERO MINIMAL SLIDING DOOR
Product Description : Sliding Door
Product Dimensions : 3000 mm (W) x 3000 mm (H)
Frame Material : Aluminium
Glass Specification : 38mm DGU (10 + 20 + 8)

Test Standards

Air Permeability BS EN 1026
Water Tightness BS EN 1027
Resistance to Wind Load BS EN 12211

Air Permeability – BS EN 12207


Class 4
(5.77 m³/hr/m² @ 600 Pa)

Water Tightness – BS EN 12208

Class 7A
(+300 Pa)

Resistance to Wind Load – BS EN 12210

Class CE₂₅₀₀
(+2500 Pa)



Tested by

Authorize Signatory

A. Sharanrao
SHARANRAO
Quality Manager

B. Methan Prabhu
B. METHAN PRABHU
General Manager



Winwall Technology India Private Limited
Laboratory Address:
No.567-A, S R Kandigai Road, Gummidipoondi, 601201

India Head Office:
Flat-D, Block-1, G.Floor, Bajaj Apartments,
No.4, Nandanam Extn., Chennai, 600035

Global Head Office:
7 Tuas View close,
Singapore, 637489

Disclaimer: The data and results given are only for the described sample submitted with Winwall Technology India Pvt Ltd.